



Product Service

# Attestation of Conformity

No. N8A 118771 0022 Rev. 01

**Holder of Attestation:** **Zhejiang Sunpro Power  
Technology co., Ltd**  
Qinggang Technological Ind.Zone  
317606 Yuhuan, Zhejiang Province  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Mono-Crystalline Silicon Photovoltaic Module**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704062309506-01

**Date,** 2024-06-28

( Zhulin Zhang )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

# Attestation of Conformity

No. N8A 118771 0022 Rev. 01

## Model(s):

SPDGxxx-144M10, SPDGxxxA-144M10, xxx=520-565, in steps of 5  
 SPDGxxx-132M10, SPDGxxxA-132M10, xxx=480-515, in steps of 5  
 SPDGxxx-120M10, SPDGxxxA-120M10, xxx=435-470, in steps of 5  
 SPDGxxx-108M10, SPDGxxxA-108M10, xxx=390-420, in steps of 5  
 SPDGxxx-N156M10, SPDGxxxA-N156M10, xxx=595-640, in steps of 5  
 SPDGxxx-N144M10, SPDGxxxA-N144M10, xxx=545-590, in steps of 5  
 SPDGxxx-N132M10, SPDGxxxA-N132M10, xxx=510-540, in steps of 5  
 SPDGxxx-N120M10, SPDGxxxA-N120M10, xxx=455-490, in steps of 5  
 SPDGxxx-N108M10, SPDGxxxA-N108M10, xxx=410-440, in steps of 5  
 SPDGxxx-132M12, SPDGxxxA-132M12, xxx=635-675, in steps of 5  
 SPDGxxx-120M12, SPDGxxxA-120M12, xxx=580-610, in steps of 5  
 SPDGxxx-110M12, SPDGxxxA-110M12, xxx=530-560, in steps of 5  
 SPDGxxx-N132M12, SPDGxxxA-N132M12, xxx=670-710, in steps of 5  
 SPDGxxx-N120M12, SPDGxxxA-N120M12, xxx=610-645, in steps of 5  
 SPDGxxx-N110M12, SPDGxxxA-N110M12, xxx=560-590, in steps of 5  
 SPDGxxx-144M, SPDGxxxA-144M, xxx=410-460, in steps of 5  
 SPDGxxx-120M, SPDGxxxA-120M, xxx=340-385, in steps of 5  
 SPDGxxx-N156R10, SPDGxxxA-N156R10, xxx=610-645, in steps of 5  
 SPDGxxx-N144R10, SPDGxxxA-N144R10, xxx=565-595, in steps of 5  
 SPDGxxx-N132R10, SPDGxxxA-N132R10, xxx=520-545, in steps of 5  
 SPDGxxx-N120R10, SPDGxxxA-N120R10, xxx=470-500, in steps of 5  
 SPDGxxx-N108R10, SPDGxxxA-N108R10, xxx=420-450, in steps of 5  
 SPDGxxx-N144RL10, SPDGxxxA-N144RL10, xxx=575-610, in steps of 5  
 SPDGxxx-N132RL10, SPDGxxxA-N132RL10, xxx=530-560, in steps of 5  
 SPDGxxx-N120RL10, SPDGxxxA-N120RL10, xxx=480-510, in steps of 5  
 SPDGxxx-N108RL10, SPDGxxxA-N108RL10, xxx=430-460, in steps of 5  
 SPDGxxx-N144RX10, SPDGxxxA-N144RX10, xxx=600-640, in steps of 5  
 SPDGxxx-N132RX10, SPDGxxxA-N132RX10, xxx=550-590, in steps of 5  
 SPDGxxx-N132R12, SPDGxxxA-N132R12, xxx=575-620, in steps of 5  
 SPDGxxx-N120R12, SPDGxxxA-N120R12, xxx=525-565, in steps of 5  
 SPDGxxx-N108R12, SPDGxxxA-N108R12, xxx=470-505, in steps of 5  
 SPDGxxx-N96R12, SPDGxxxA-N96R12, xxx=420-450, in steps of 5  
 xxx is standing for rated output power at STC

## Parameters:

Construction: Framed, double glass with Junction box, Cable and Connectors.  
 Safety Class: Class II  
 Maximum System Voltage: 1500 V DC  
 Fire Safety Class: Class A or Class C according to UL790  
 Changzhou HuaYang Inspection and Testing Technology Co., Ltd  
 Test Laboratory: NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China

## Tested according to:

EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.